

Reference number: Erf 21/195, George  
Date: 03/02/2025

Enquiries: M Geyer  
044 801 9278

**ATTENTION: MR N AGENBAG**

**Kantey & Templer Pty Ltd**  
**PO Box 458**  
**George**  
**6530**

**ERF 21/195, KRAAIBOSCH GEORGE: PROPOSED DEVELOPMENT**

**AVAILABILITY OF BULK WATER AND SEWER INFRASTRUCTURE & ASSOCIATED COSTS AND CHARGES**

Your request dated 17 March 2023 to accommodate the proposed development in the George Municipal water and sewer system and your subsequent request of 30 January 2025 of an update on the accommodation of the proposed development refers.

For ease of reference, changes from the original letters commissioning or completion of infrastructure upgrades are indicated in **red text**.

The George Municipality confirms that the proposed development was taken into consideration in the current water and sanitation master plans as part of the Kraaibosch development area.

A technical report was prepared by GLS dated 13 June 2023, attached to this letter as annexure A, B and C to confirm water and sanitation system upgrades required to support the proposed development.

**PROPOSED DEVELOPMENT**

The proposed implementation plan of the development, received as part of the technical report is included in Annexure A.

**WATER AND SEWER BULK INFRASTRUCTURE CAPACITY**

In line with general growth and demand, new supporting bulk infrastructure must be constructed, and existing infrastructure upgraded where necessary to accommodate the services demand of all new developments in George.

The capacity of the treatment works, and bulk infrastructure is discussed below.

**Treatment Works**

**a) Water Treatment:**

- The Water Treatment Works (old and new) is currently operating under constraint.
- A  $\pm 4.5$ MI/day capacity upgrade of the old treatment works has been **completed**.
- A 20MI/day capacity upgrade of the new treatment works is in progress with an estimated completion date in the **first quarter of 2025**.
- The treatment works will have sufficient capacity for the development in its entirety once the  $\pm 20$ MI/day capacity upgrade is commissioned.



Should a phased development be proposed, the Municipality will consider the demand per phase vs availability at the time.

**b) Wastewater Treatment:**

- The Outeniqua Wastewater Treatment works has sufficient capacity to support the development.

**Bulk Pipelines and Pump Stations**

**a) Water**

- Kraaibosch reservoir and tower reservoirs: The development falls within the George Main Zone that supplies the Kraaibosch reservoir and tower zone. Sufficient spare capacity exists within the zones.

**b) Sanitation**

- Meul Pump Station and Rising Main: The pump station and a portion of the rising main is currently under development, with an anticipated commissioning date of **August 2025**. The pump station and rising main is operating near capacity. The pump station and associated rising main will have sufficient capacity for the development in its entirety once the upgrade to the pump station and rising main is commissioned.
- Schaapkop Pump Station and Rising Main: The pump station and a portion of the rising main is currently under development, with an anticipated commissioning date of **January 2026**. The pump station and rising main is operating near capacity. The pump station and associated rising main will have sufficient capacity for the development in its entirety once the upgrade to the pump station and rising main is commissioned.
- Kraaibosch Pump Station: The pump station has sufficient capacity to support the development. The upgrading of the pump station is not planned for implementation until 2036.

Should a phased development be proposed, the Municipality will consider the demand per phase vs availability at the time.

**COMMENCEMENT OF DEVELOPMENT**

The development, in its entirety or in phases, is subject to confirmation by the Director: Civil Engineering Services regarding the availability of water supply & treatment capacity and sanitation bulk conveyance & treatment capacity at the time of the development implementation, or if developed in phases before the commencement of each phase.

A development/implementation program is to be provided by the Developer when requesting confirmation of the capacity from the Director: Civil Engineering Services. If the Developer does not adhere to the program provided and approved by the Director: Civil Engineering Services, the Director: Civil Engineering Services will be entitled to revise the availability of such bulk capacity.

No development may connect to the municipal water and sewer system unless the required bulk and link infrastructure is available, and a services agreement is signed between the Developer and the Municipality.

**Water and Sewer Bulk Infrastructure Upgrades Required**

The summary of the technical report concludes that the total pro-rata cost for water and sewer infrastructure upgrades in support of the development amounts to R 11 850 000.00 excluding VAT.

It should be noted that upgrades to the bulk sanitation infrastructure includes interim arrangements (section 4.4.3 of the technical report) until such time that the infrastructure of the neighbouring development to the East, Erf 3/195 is in place to allow drainage of the development. The interim infrastructure requirements are considered development specific and will be for the full account of the developer.

Table 2: Summary of General and Development Specific Upgrade to the Water and Sewer System

Description	Report reference	Water (excl. VAT)	Sewer (excl. VAT)	Total (excl. VAT)
General items to address existing problems: Bulk System	3.4.1	R 2 409 000.00	R 2 879 000.00	R 5 288 000.00



Description	Report reference	Water (excl. VAT)	Sewer (excl. VAT)	Total (excl. VAT)
Development Specific items: Distribution / Reticulation System	-	R 0.00	R 0.00	R 0.00
General items to address existing problems: Distribution / Reticulation System	4.4.1	R 0.00	R 9 000.00	R 9 000.00
Development Specific items: Distribution / Reticulation System	3.5.2 4.4.2	R 1 756 000.00	R 4 797 000.00	R 6 553 000.00
<b>Total</b>		<b>R 4 165 000.00</b>	<b>R 7 685 000.00</b>	<b>R 11 850 000.00</b>

#### Reimbursement of expenditure

In term of section 66(4) of the Planning By-law, the Developer will be required to make a proportional contribution to municipal public expenditure according to the normal need arising from the approval. The Developer will be reimbursed for the actual expenditure incurred for any services provided by the Developer above the normal need, up to the maximum value equal to the applicable Development Charges calculated for the services as per the approval, subject to normal escalation.

For this development, the development specific items required are confirmed in sections 3.5.2, 4.4.2 and 4.4.3 (interim requirements) of the technical report.

#### Availability of bulk services

Some of the bulk water and sewer system items are currently being addressed, i.e., the extension of the capacity of the Water Treatment Works, the Meul and Schaapkop pump stations and associated rising mains. Development Contributions payable by the Developer will cover the cost of the pro-rated development contribution of these infrastructure items.

However, the remaining items (referred to as general items in the technical report) must be addressed to accommodate the development and are to be constructed by the Developer. The pro-rata amount more than the development specific demand will be credited against the Development Contributions payable. The Developer's appointed registered Engineer will be required to submit a motivational report, indicating the quantum of services provided.

Table 3: Items to be addressed by the Developer for which credits may be applicable

Description	Estimated Cost	Estimated Pro-rata Cost	Pro-rata %	DC Credit % of actual cost
<b>Water (refer to section 3.5.1 and 3.5.2)</b>				
General items to address existing problems: Bulk Water System <sup>A</sup>	R 360 721 000	R 2 409 000	0.67%	99.33%
Development Specific items: Water Distribution System	R 1 756 000	R 1 756 000	100%	0%
<b>Sewer (refer to section 4.3.1, 4.4.1 and 4.4.2)</b>				
General items to address existing problems: Bulk Sewer System <sup>A</sup>	R 264 873 000	R 2 879 000	1.09%	98.91%
General items to address existing problems: Sewer System	R 423 000	R 9 000	2.13%	97.87%
Development specific items: Sewer System	R 14 855 000	R 4 797 000	32.29%	0%

#### Notes:

The above costs are indicative only and will vary according to actual cost of construction.

<sup>A</sup> Under construction by George Municipality



### **Link services requirements**

The Developer will not be entitled for any reimbursement relating to the provision of any link and/or internal services.

A portion of the sanitation infrastructure of the development is dependent on the neighbouring development to the East, Erf 3/195. The Developer will be required to construct, operate, and maintain such interim sanitation infrastructure at own cost until such time that the sanitation infrastructure of Erf 3/195 is commissioned. The interim infrastructure requirements and those ultimate infrastructure requirements to connect to Erf 3/195 and Erf 88/195 are considered development specific and will be for the account of the developer.

### **Development Charges**

The current total development charges (DCs) relating to Civil Engineering Services (roads, water, and sanitation services only), and in accordance with the current guidelines, for the proposed development were calculated on 26 October 2022 and amount to R 8 762 098.73 excluding VAT. This amount includes for water, sanitation, and road development contributions applicable at the time of approval of the development.


The Developer is reminded of the following Clause relating to the calculation of development charges:

*"Any amendments or additions to the proposed development which is not contained within the calculation sheet as stated in clause 2 above which might lead to an increase in the proportional contribution to municipal public expenditure, will result in the recalculation of the development charges and the amendment of these conditions of approval or the imposition of other relevant conditions of approval."*

In addition, the development charges amount is subject to amendment based on annual escalation and applicable at the time that development contributions are due for payment. The Council has an approved Development Contributions Policy and guidelines for the calculation of DCs.

Kindly confirm your acceptance of the above in writing.

Yours faithfully,



**JANNE KOEGELENBERG**  
**DIRECTOR: CIVIL ENGINEERING SERVICES**





Frank Tamboer  
Manager: Refuse Removal & Ablutions  
Environmental Services  
Directorate: Community Services  
ftamboer@george.gov.za  
Tel: +27 (0)44: 802 2900

## **DIRECTORATE: COMMUNITY SERVICES**

**Date: 05 December 2024**

**Enquiries: Frank Tamboer**

Kantey & Templer Consulting Engineers  
PO Box 458  
George  
6530

**Attention: Nelius Agenbag**

**RE: G5215BA: Pieterkoen Development, Residential Estate, Portion 21 of Farm 195, Kraaibosch.**

The above-mentioned subject bear's reference:

You request was favourable considered as per George Municipality: Integrated Waste Management By Law, Provincial Gazette Extraordinary, 8897, Friday 22<sup>nd</sup> March 2024.

### **“Chapter 3, Provision of Waste Management Services:**

#### **Collection of unsuitable waste**

12. A person may not place waste identified in terms of section 10(2)(d) for collection, either on its own or mixed with any other waste for which the Municipality provides collection services, unless prior arrangement is made with the Municipality for special collection by the Municipality or a service provider.

#### **Bulk refuse collection at secured complexes and businesses**

13. The developer must provide a secured refuse area at an accessible area and must meet the guidelines provided by the municipality. Waste must be store as per the separation at source requirements.”

We hereby confirm that George Municipality, Community Services, Environmental Services, Refuse Collection has the capacity and will render the services as requested.

You are requested when the developer has finalized the building process that you formally notify the office on (044) 802 2900 Environmental Services to start with collection

We trust that the above-mentioned is sufficient for your purposes and to comply with the George Municipality: Integrated Waste Management By Law, Provincial Gazette Extraordinary, 8897, Friday 22<sup>nd</sup> March 2024.

Regards

.....  
**MANAGER: REFUSE & ABLUTIONS**  
**FRANK TAMBOER**



**RE: G5215BA: Pieterkoen Development, Residential Estate, Portion 21 of Farm 195, Kraaibosch.**



.....  
**SENIOR MANAGER: ENVIRONMENTAL SERVICES**  
**SIVUYILE MTILA**

.....  
**DIRECTOR: COMMUNITY SERVICES**  
**DAWIE ADONIS**

Reference number: Erf 21/195, George  
Date: 7/25/2023

Enquiries: M Geyer  
044 801 9278

**ATTENTION: MR N AGENBAG**

**Kantey & Templer Pty Ltd**  
**PO Box 458**  
**George**  
**6530**

**ERF 21/195, KRAAIBOSCH GEORGE: PROPOSED DEVELOPMENT**

**AVAILABILITY OF BULK WATER AND SEWER INFRASTRUCTURE & ASSOCIATED COSTS AND CHARGES**

Your request dated 17 March 2023 to accommodate the proposed development in the George Municipal water and sewer system refers.

The George Municipality confirms that the proposed development was taken into consideration in the current water and sanitation master plans as part of the Kraaibosch development area.

A technical report was prepared by GLS dated 13 June 2023, attached to this letter as annexure A, B and C to confirm water and sanitation system upgrades required to support the proposed development.

**PROPOSED DEVELOPMENT**

The proposed implementation plan of the development, received as part of the technical report is included in Annexure A.

**WATER AND SEWER BULK INFRASTRUCTURE CAPACITY**

In line with general growth and demand, new supporting bulk infrastructure must be constructed, and existing infrastructure upgraded where necessary to accommodate the services demand of all new developments in George.

The capacity of the treatment works, and bulk infrastructure is discussed below.

**Treatment Works**

**a) Water Treatment:**

- The Water Treatment Works (old and new) is currently operating under constraint.
- A  $\pm 4.5$ MI/day capacity upgrade of the old treatment works is in progress with an estimated completion date of August 2023. A 20MI/day capacity upgrade of the new treatment works is in progress with an estimated completion date in the first part of 2025.
- The treatment works will have sufficient capacity for the development in its entirety once the  $\pm 20$ MI/day capacity upgrade is commissioned.

Should a phased development be proposed, the Municipality will consider the demand per phase vs availability at the time.



**b) Wastewater Treatment:**

- The Outeniqua Wastewater Treatment works has sufficient capacity to support the development.

**Bulk Pipelines and Pump Stations**

**a) Water**

- Kraaibosch reservoir and tower reservoirs: The development falls within the George Main Zone that supplies the Kraaibosch reservoir and tower zone. Sufficient spare capacity exists within the zones.

**b) Sanitation**

- Meul Pump Station and Rising Main: The pump station and a portion of the rising main is currently under development, with an anticipated commissioning date of October 2024. The pump station and rising main is operating near capacity. The pump station and associated rising main will have sufficient capacity for the development in its entirety once the upgrade to the pump station and rising main is commissioned.
- Schaapkop Pump Station and Rising Main: The pump station and a portion of the rising main is currently under development, with an anticipated commissioning date of June 2025. The pump station and rising main is operating near capacity. The pump station and associated rising main will have sufficient capacity for the development in its entirety once the upgrade to the pump station and rising main is commissioned.
- Kraaibosch Pump Station: The pump station has sufficient capacity to support the development. The upgrading of the pump station is not planned for implementation until 2036.

Should a phased development be proposed, the Municipality will consider the demand per phase vs availability at the time.

**COMMENCEMENT OF DEVELOPMENT**

The development, in its entirety or in phases, is subject to confirmation by the Director: Civil Engineering Services regarding the availability of water supply & treatment capacity and sanitation bulk conveyance & treatment capacity at the time of the development implementation, or if developed in phases before the commencement of each phase.

A development/implementation program is to be provided by the Developer when requesting confirmation of the capacity from the Director: Civil Engineering Services. If the Developer does not adhere to the program provided and approved by the Director: Civil Engineering Services, the Director: Civil Engineering Services will be entitled to revise the availability of such bulk capacity.

No development may connect to the municipal water and sewer system unless the required bulk and link infrastructure is available, and a services agreement is signed between the Developer and the Municipality.

**Water and Sewer Bulk Infrastructure Upgrades Required**

The summary of the technical report concludes that the total pro-rata cost for water and sewer infrastructure upgrades in support of the development amounts to R 11 850 000.00 excluding VAT.

It should be noted that upgrades to the bulk sanitation infrastructure includes interim arrangements (section 4.4.3 of the technical report) until such time that the infrastructure of the neighbouring development to the East, Erf 3/195 is in place to allow drainage of the development. The interim infrastructure requirements are considered development specific and will be for the full account of the developer.

Table 2: Summary of General and Development Specific Upgrade to the Water and Sewer System

Description	Report reference	Water (excl. VAT)	Sewer (excl. VAT)	Total (excl. VAT)
General items to address existing problems: Bulk System	3.4.1	R 2 409 000.00	R 2 879 000.00	R 5 288 000.00
Development Specific items: Distribution / Reticulation System	-	R 0.00	R 0.00	R 0.00





Description	Report reference	Water (excl. VAT)	Sewer (excl. VAT)	Total (excl. VAT)
General items to address existing problems: Distribution / Reticulation System	4.4.1	R 0.00	R 9 000.00	R 9 000.00
Development Specific items: Distribution / Reticulation System	3.5.2 4.4.2	R 1 756 000.00	R 4 797 000.00	R 6 553 000.00
<b>Total</b>		<b>R 4 165 000.00</b>	<b>R 7 685 000.00</b>	<b>R 11 850 000.00</b>

#### Reimbursement of expenditure

In term of section 66(4) of the Planning By-law, the Developer will be required to make a proportional contribution to municipal public expenditure according to the normal need arising from the approval. The Developer will be reimbursed for the actual expenditure incurred for any services provided by the Developer above the normal need, up to the maximum value equal to the applicable Development Charges calculated for the services as per the approval, subject to normal escalation.

For this development, the development specific items required are confirmed in sections 3.5.2, 4.4.2 and 4.4.3 (interim requirements) of the technical report.

#### Availability of bulk services

Some of the bulk water and sewer system items are currently being addressed, i.e., the extension of the capacity of the Water Treatment Works, the Meul and Schaapkop pump stations and associated rising mains. Development Contributions payable by the Developer will cover the cost of the pro-rated development contribution of these infrastructure items.

However, the remaining items (referred to as general items in the technical report) must be addressed to accommodate the development and are to be constructed by the Developer. The pro-rata amount more than the development specific demand will be credited against the Development Contributions payable. The Developer's appointed registered Engineer will be required to submit a motivational report, indicating the quantum of services provided.

Table 3: Items to be addressed by the Developer for which credits may be applicable

Description	Estimated Cost	Estimated Pro-rata Cost	Pro-rata %	DC Credit % of actual cost
<b>Water (refer to section 3.5.1 and 3.5.2)</b>				
General items to address existing problems: Bulk Water System <sup>A</sup>	R 360 721 000	R 2 409 000	0.67%	99.33%
Development Specific items: Water Distribution System	R 1 756 000	R 1 756 000	100%	0%
<b>Sewer (refer to section 4.3.1, 4.4.1 and 4.4.2)</b>				
General items to address existing problems: Bulk Sewer System <sup>A</sup>	R 264 873 000	R 2 879 000	1.09%	98.91%
General items to address existing problems: Sewer System	R 423 000	R 9 000	2.13%	97.87%
Development specific items: Sewer System	R 14 855 000	R 4 797 000	32.29%	0%

#### Notes:

The above costs are indicative only and will vary according to actual cost of construction.

<sup>A</sup> Under construction by George Municipality

#### Link services requirements

The Developer will not be entitled for any reimbursement relating to the provision of any link and/or internal services.



A portion of the sanitation infrastructure of the development is dependent on the neighbouring development to the East, Erf 3/195. The Developer will be required to construct, operate, and maintain such interim sanitation infrastructure at own cost until such time that the sanitation infrastructure of Erf 3/195 is commissioned. The interim infrastructure requirements and those ultimate infrastructure requirements to connect to Erf 3/195 and Erf 88/195 are considered development specific and will be for the account of the developer.

### Development Charges

The current total development charges (DCs) relating to Civil Engineering Services (roads, water, and sanitation services only), and in accordance with the current guidelines, for the proposed development were calculated on 26 October 2022 and amount to R 8 762 098.73 excluding VAT. This amount includes for water, sanitation, and road development contributions applicable at the time of approval of the development.

The Developer is reminded of the following Clause relating to the calculation of development charges:

*"Any amendments or additions to the proposed development which is not contained within the calculation sheet as stated in clause 2 above which might lead to an increase in the proportional contribution to municipal public expenditure, will result in the recalculation of the development chargers and the amendment of these conditions of approval or the imposition of other relevant conditions of approval."*

In addition, the development charges amount is subject to amendment based on annual escalation and applicable at the time that development contributions are due for payment. The Council has an approved Development Contributions Policy and guidelines for the calculation of DCs.

Kindly confirm your acceptance of the above in writing.

Yours faithfully,



**JANNIE KOEGELENBERG**  
**DIRECTOR: CIVIL ENGINEERING SERVICES**

### ANNEXURES

- A Technical report by GLS (13 June 2023)
- B Figure 1 Required works - Water: George Erf 195 Portion 21
- C Figure 2 Required works - Sewer: George Erf 195 Portion 21



## Carla Swanepoel

---

**From:** Daniel Greeff <Dgreeff@george.gov.za>  
**Sent:** Tuesday, 25 October 2022 16:48  
**To:** rob@dvmgeo.co.za  
**Cc:** Rasmus Esterhuysen  
**Subject:** RE: External Email > : George: Pieterkoen Development: Capacity and DC Request  
**Attachments:** Groenkloof.pdf; Kraaibosch 2.pdf; Kraaibosch 1.pdf

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Mr Hall,

There is a proposed switching substation site (erf 26012) adjacent to the development.  
The development will connect directly to the switching substation via a 185/3 AL 11kV underground cable that will supply adjacent developments as well.  
We can discuss further at the meeting.

Kind Regards  
Danie Greeff Pr.Eng  
Electro-Technical Services: Deputy Director – Planning & Design

Office: 044 874 3917  
Cell: 061 037 9496  
Email: [dgreeff@george.gov.za](mailto:dgreeff@george.gov.za)



---

**From:** rob@dvmgeo.co.za <rob@dvmgeo.co.za>  
**Sent:** Tuesday, 18 October 2022 09:26  
**To:** Daniel Greeff <Dgreeff@george.gov.za>  
**Subject:** External Email > : George: Pieterkoen Development: Capacity and DC Request

**Caution:** This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Morning Danie

Trust you are keeping well!

Attached a capacity and DC calculation request for the above-mentioned development

Please advise at your earliest convenience and confirm receipt



**CONFIDENTIALITY & DISCLAIMER NOTICE** The information contained in this message is confidential and is intended for the addressee(s) only. If you have received this message in error or there are any problems please notify the originator immediately. The unauthorized use, disclosure, copying or alteration of this message is strictly forbidden. George Municipality will not be liable for direct, special, indirect or consequential damages arising from alteration of this message by a third party or as a result of any malicious code or virus being passed on. If you have received this message in error, please notify the sender immediately by email, facsimile or telephone and return and/or destroy the original message. \*\*\*\*\* Privacy policy George Municipality implements a privacy policy aimed at protecting visitors to our social media sites. POPIA We respect the privacy rights of everyone who uses or enquires about our services. Protecting your personal information, as defined in the Protection of Personal Information Act, Act 4 of 2013, will be respected. Personal information will only be shared for purposes of resolving customer enquiries, providing customer services or for any other legitimate purpose relating to George Municipal functions. For your reference, the POPI and PAIA Acts are available at [www.gov.za/documents/acts](http://www.gov.za/documents/acts) with amendments listed on [www.acts.co.za](http://www.acts.co.za)