



**HARTLAND II (JAKKALSOP) ESTATE  
REMAINDER OF THE FARM VAALE VALLEY 219  
MOSSEL BAY**



**HIGH LEVEL BULK ENGINEERING SERVICES  
REPORT**

**REVISION 1**

**MAY 2025**



**George Office**  
**Western Cape**

Tel: +27 44 884 1138

Fax: +27 44 884 1185

82 Victoria Street, George, 6529

PO Box 9962, George, 6530

[www.eceng.co.za](http://www.eceng.co.za)

**HARTLAND II (JAKKALS KOP) ESTATE  
REMAINDER OF THE FARM VAALE VALLEY 219  
MOSSEL BAY**

**HIGH LEVEL BULK ENGINEERING SERVICES  
REPORT**


**REVISION 1**

**MAY 2025**



PREPARED FOR:

Hartland Lifestyle Estate (Pty) Ltd.  
Unit 1 K109 Business Park  
1 Tinus de Jongh Street  
Van Eck Park Extension 2  
Brakpan  
1541



PREPARED BY:

Element Consulting Engineers  
PO Box 9962  
GEORGE  
6530  
82 Victoria Street

# DOCUMENT CONTROL SHEET

<b>Compiled By:</b>	..... Hannes Lourens PrEng	..... Date
<b>Reviewed By:</b>	..... Jako Fourie PrEng	..... Date

Revision	Description	Date Issued	Revision By:
0	Support to various commencement discussions	June 2024	HL
1	Updates to SDP	May 2025	HL

## DISTRIBUTION LIST

Name	Company	Email	Tel

**HARTLAND II (JAKKALSKOP) ESTATE  
REMAINDER OF THE FARM VAALE VALLEY 219  
MOSSEL BAY**

**HIGH LEVEL BULK ENGINEERING SERVICES REPORT**

**REVISION 1**

**CONTENTS**

---

<b>Chapter</b>	<b>Description</b>	<b>Page</b>
<b>1</b>	<b>INTRODUCTION</b>	<b>3</b>
	1.1 Background	3
	1.2 Purpose of the report	3
	1.3 Locality and layout	3
	1.4 Site Development Plan	5
	1.5 Proposed land use	5
<b>2</b>	<b>GEOTECHNICAL INVESTIGATION</b>	<b>6</b>
<b>3</b>	<b>ENGINEERING SERVICES</b>	<b>7</b>
	3.1 Services agreement	7
	3.2 Water	7
	3.2.1 Water Demand	7
	3.2.2 Bulk Availability	7
	3.2.3 Connection Point	7
	3.2.4 Design Criteria and Standard of Engineering Services	7
	3.2.5 Bulk water layout	8
	3.2.6 Internal bulk water preliminary design drawing	8
	3.3 Sewer	9
	3.3.1 Site layout considerations	9
	3.3.2 Design flow	10
	3.3.3 Connection point, pressure line and sewer pumpstation	10
	3.3.4 Capacity at Hartenbos regional WWTW	11
	3.3.5 Design Criteria and Standards of Engineering Services	11
	3.3.6 Internal bulk sewer preliminary design drawing	12
	3.4 Roads and access	12
	3.4.1 Access	12
	3.4.2 Access configuration	13
	3.4.3 Internal Standards and Design Criteria	13
	3.4.4 Preliminary design drawing	14

3.4.5	Traffic Impact Assessment	14
3.4.6	Public transport facilities	14
3.4.7	Parking	15
3.5	Stormwater	15
3.5.1	Site layout considerations and internal drainage	15
3.5.2	External stormwater drainage	15
3.5.3	Internal design, standards and criteria	16
3.5.4	Stormwater preliminary design drawing	17
3.6	Solid Waste	18
3.7	Electricity	18
3.7.1	Bulk Supply	18
3.7.2	Maximum Demand	19
3.7.3	Internal Medium Voltage (MV) Reticulation	20
3.7.4	Internal Low Voltage (LV) Reticulation	20
3.7.5	Street Lighting	21
3.7.6	Data Reticulation	21
<b>4</b>	<b>CONCLUSIONS AND RECOMMENDATIONS</b>	<b>22</b>
4.1	Conclusions	22
4.2	Recommendations	25
<b>5</b>	<b>ADDENDA</b>	<b>26</b>
5.1	Addendum 1: Site Development Plan	26
5.2	Addendum 2: Preliminary Bulk Engineering Services Design Drawings	26
5.3	Addendum 3: Municipal Confirmation Letters	26

# **1 INTRODUCTION**

---

## **1.1 Background**

Element Consulting Engineers has been appointed for the rendering of the multi-disciplinary package of professional engineering services for the development of the Hartland II (Jakkalskop) Estate.

## **1.2 Purpose of the report**

This report will detail and discuss the high level bulk engineering services of the proposed development and is intended to be utilized for the Environmental Impact Assessment (EIA) application as well as the Town Planning Application.

## **1.3 Locality and layout**

The development is situated on Remainder of farm Vaale Valley 219, Mossel Bay, approximately 11km north of Mossel Bay and 34km west of George.

The farm is bound by Outeniquasbosch Estate (Farm 248 Oude Duinzigt) to the north-west, Monte Christo Residential Estate to the west, New Vintage Residential Estate (Portion 99 of Farm Hartenbosch 217) to the south-west, National Road 2 (N2) as well as the R102 (MR344) to the south-east and the Klein Brak River to the north-east.

Access is obtained from the R102 (MR344) on the south-eastern boundary.

The locality and layout of the development, in relation to the adjacent road network and developments, is indicated in the figure below.




Figure 1: Locality plan



Figure 2: Layout plan

## 1.4 Site Development Plan

A Site Development Plan (SDP) has been prepared and is presented in the following diagram and is attached to the report as addendum.



Figure 3: Site Development Plan (SDP)

## 1.5 Proposed land use

The proposed development envisages the following:

- Hospital – 200 beds
- School – 2600 students
- Tertiary Education Centre – 450 students
- Hostels – 136 students

## 2 GEOTECHNICAL INVESTIGATION

---

A formal geotechnical investigation has been commissioned and has been conducted by Terra Geotechnical Services. The full report is available upon request. Holistically, the conclusion is reached that the in-situ materials found on site are adequate for the construction of engineering services and foundations for commercial development.

### **Slope Stability**

Gradients on the site are flat to undulating. No natural slope instability is present.

### **Ground water and stormwater**

No ground water and/or perched water are evident. A high water retention rate is expected. Lateral movement of stormwater will be moderate due to the flat to undulating gradient. Erosion of the silty sands may occur. A number of drainage lines crosses the development footprint and need to be incorporated into the SDP of the development. A number of existing farm dams may be repurposed as stormwater detention dams and incorporated into the stormwater management plan (SMP) and SDP of the development.

### **Engineering Services**

A TLB will suffice for trenching and excavations of all services and foundations in all materials.

### **Foundations for commercial and institutional development**

The in-situ materials are adequate to support commercial and institutional development. A combination of medium reinforced raft foundations, medium strip footings and medium reinforced concrete column foundations will be adequate for the development. Fill areas to be adequately compacted to a minimum specification.

### **3 ENGINEERING SERVICES**

---

This chapter will discuss the high level bulk engineering services of the development as well as the engineering standards and technical design criteria applicable to the project.

#### **3.1 Services agreement**

A services agreement (SA) will be signed between the developer and the municipality on conclusion of the EIA and townplanning processes. This bulk services engineering report, as well as inputs from the EIA and townplanning processes, will form the basis of the SA.

#### **3.2 Water**

##### **3.2.1 Water Demand**

The Average Annual Daily Demand (AADD) for the development, in line with accepted design consumptions, assumptions, criteria and standards, is 337kl/day.

##### **3.2.2 Bulk Availability**

Bulk water is available for this development. A letter of confirmation has been requested from the Mossel Bay Municipality.

##### **3.2.3 Connection Point**

The development is serviced by the new municipal 7Ml Jakkalskop Reservoir, situated centrally on the highest point on the proposed development.

The new Jakkalskop reservoir feeds into a new 500mm municipal uPVC bulk water line that has recently been constructed along the R102 (MR344) on the south eastern boundary of the development.

The bulk water connection to the development may be at any of a number of positions, along the new 500mm line. The bulk water connection for the school and hospital will be from a new line along the new access road. The bulk water connection for the tertiary education centre is proposed at a point adjacent to the centre on the R102 (MR344).

##### **3.2.4 Design Criteria and Standard of Engineering Services**

- AADD Design consumption
  - Hospital – 0.6kl/bed
  - School – 60l/student
  - Tertiary Education Centre – 60l/student
  - Hostel – 240l/student

- Peak factors as prescribed
- Minimum pressures for the network are calculated for a fire flow 30l/sec and peak demand at the point of lowest pressure under peak conditions.
- Maximum of 4 valves to isolate a pipe section.
- Maximum length of 600m of main pipe per isolated section.
- Air valves provided where applicable.
- Minimum cover to pipes 900mm.
- Pipe type and class uPVC class 6 to 12, depending on network pressure.
- Pipe diameters varying between 90mm and 200mm depending on pressure available and flow required.
- Erf connections HDPE Class 10.
- Erven serviced with a 20mm connection and Aqua-Loc box and meter.
- Fire hydrants provided in accordance with relevant guidelines and legislation.

### 3.2.5 Bulk water layout

The bulk water layout is presented in the following diagram.




Figure 4: Reservoir and bulk water line

### 3.2.6 Internal bulk water preliminary design drawing

The bulk water preliminary design drawing is presented in the following diagram and is attached as addendum to the report.



Figure 5: Bulk water preliminary design drawing

### 3.3 Sewer

#### 3.3.1 Site layout considerations

The proposed development spans over a number of watersheds and a number of drainage zones are identified. Each zone will be serviced with a gravity sewer network and pump station. The primary drainage zone drains towards the southernmost corner of the site adjacent to the R102 (MR344) and is indicated diagrammatically in the figure below.



Figure 6: Primary sewer drainage

### 3.3.2 Design flow

The Average Dry Weather Flow (ADWF) of the development, in line with accepted design criteria and standards, is 304kl/d.

The design peak flow, inclusive of a specified peak factor of 3.0 and 15% extraneous flow, will be calculated during detail design stage.

### 3.3.3 Connection point, pressure line and sewer pumpstation

The site is not serviced by a municipal sewer connection or a municipal sewer network in close vicinity.

A new main sewer pump station (Pump Station 1 – PS1) shall be constructed in the southern corner of the proposed development. Sewer will be pumped from here to the Hartenbos Regional WWTW with a new pressure line. The routing of the new pressure line shall be finalized with the municipality during the detail design stage, but shall in concept be as per the diagram below.



Figure 7: Sewer PS1 and pressure line to Hartenbos Regional WWTW

### 3.3.4 Capacity at Hartenbos regional WWTW

Hartenbos regional WWTW has sufficient capacity to accommodate the bulk sewer from the development. A letter of confirmation has been requested from the Mossel Bay Municipality.

### 3.3.5 Design Criteria and Standards of Engineering Services

- The following design flows are utilized:
  - Hospital – 0.54kl/bed
  - School – 54l/student
  - Tertiary Education Centre – 54l/student
  - Hostel – 220l/student
- Specified peak factor of 3.0
- Allowance for 15% extraneous flow
- A conventional waterborne sewerage system is provided.
- Minimum flow velocities designed for as 0.7m/s.
- Minimum cover to all pipes of 800mm.
- Pipe diameters of generally 110mm for all service connections and minor lines and 250mm for main lines, as required per the detailed designs.
- Minimum design gradients as follows:

Units	Grade
1	1:60
1-5	1:80
6-10	1:100
11-80	1:120
81-110	1:150



Primary access for phase 1 will be obtained from km2.763 at the existing formalized Hartland Estate access. Secondary access for phase 1 will be obtained from km2.299.

The necessary applications will be lodged to the Provincial Roads Authority for the formalization of these accesses.

The access points are indicated in the following diagram.




Figure 9: Access to the development from the R102 (MR344)

### 3.4.2 Access configuration

In accordance with provincial roads guidelines, the access configuration for the accesses onto the R102 (MR344) shall be a full access with stop control from the development. The accesses will trigger right turn lanes on the R102 (MR344). The length of the right turn lane shall be a nominal length to be determined through negotiations with the provincial roads' authority, in line with minimum geometric standards. All of the above to be determined during the detail design stage.

### 3.4.3 Internal Standards and Design Criteria

Internal standards and design criteria are specified as follows:

- Internal road widths of between 5.2m and 7.4m, depending on road class
- Asphalt surfacing 30mm.
- Pavement structural materials to be imported from commercial sources.
- All minimum radii at bellmouths to be 8m.
- Minimum road grade of 0.4% and camber of 2%.
- Road design life of 20 years.

### 3.4.4 Preliminary design drawing

The preliminary access and roads layout design drawing is presented in the following diagram and is attached as addendum to the report.



Figure 10: Preliminary access and roads layout design drawing

### 3.4.5 Traffic Impact Assessment

A Traffic Impact Assessment (TIA) will be required to be conducted for the development. The TIA will be required to be conducted in line with all provincial and municipal prescriptions and guidelines.

### 3.4.6 Public transport facilities

The provision of public transport facilities like minibus-taxi drop-off facilities to be investigated on the R102 (MR344) at the access points to the development.

### 3.4.7 Parking

Sufficient parking shall be provided on the SDP of the proposed development in line with all municipal guidelines. Parking shall be provided for disabled persons at all public and/or commercial facilities.

## 3.5 Stormwater

### 3.5.1 Site layout considerations and internal drainage

The proposed development spans over a number of watersheds and a number of drainage zones are identified. Each zone will be serviced with a formal stormwater network. The primary drainage zone drains towards the southernmost corner of the site adjacent to the R102 (MR344) and is indicated diagrammatically in the figure below. The secondary drainage zone drains towards the Little Brak River to the east and is also indicated diagrammatically in the figure below.




Figure 11: Primary stormwater drainage (south) and secondary drainage (east)

### 3.5.2 External stormwater drainage

For the primary drainage area, stormwater will be collected in a detention pond on the lowest point of the site on the southern corner. Stormwater will drain south-west in a dedicated concrete culvert, underneath Monte Christo Road, where it will drain into the

existing municipal detention pond on the municipal erf (Ptn 101 of Farm 217). Drainage from the municipal detention pond is into the Hartenbos River.

For the secondary drainage area, stormwater will drain directly into the Little Brak River.

The proposed infrastructure is indicated on the figure below:



Figure 12: External stormwater drainage: Detention Pond 1 with culvert to municipal detention pond.

### 3.5.3 Internal design, standards and criteria

A formal stormwater reticulation system will be provided by a combination of surfaced roadways, kerbs, channels, cut-off drains, stormwater pipes, detention ponds and various minor structures. Energy dissipation will be performed as standard practice with gabion mattresses at all outlets. All pipe outlets will be standard concrete headwalls. Litter traps will be provided at all stormwater outlets and will be cleaned on a regular basis by the estate's landscaping and maintenance teams.

The integrated stormwater and road system form an integral part of layout planning. The system rests on three legs, namely the minor system, the major system and the emergency system. Minor storms and normal flowoff are catered for in the normal road prism and piped system. Major storms are routed through a linked system of road prisms and public open spaces, using attenuation techniques. The emergency system recognizes failure of the minor and major systems and provides for emergency runoff by providing continuous overland flow routes to minimize flooding of residential areas.

The following standards and design criteria are relevant:

- Minor system designed for 2-year return period and conveyed in a combination of maximum 200m aboveground in the road prism and underground piped system.
- Major system designed for 50-year return period. Difference between the 50 year and 2-year flood to be conveyed in the road prism with depths not exceeding 150mm and into designated public open spaces, using attenuation techniques.
- Minimum gradients for pipelines allow minimum flow speeds of 0.7m/s at full flow.
- Maximum pipeline flow velocities are 3.5m/s.
- Stormwater pipes - 100D.
- Bedding - Class C.
- Minimum cover on pipes - 800mm.
- Minimum pipe diameter - 450mm.
- Gabion mattresses to be provided at all outlets for energy dissipation.
- Outlets to be standard concrete headwalls.

All designs will be confirmed with the municipality during the detail design stage.

### 3.5.4 Stormwater preliminary design drawing

The stormwater preliminary design drawing is presented in the following diagram and is attached as addendum to the report.



Figure 13: Stormwater preliminary design drawing

### **3.6 Solid Waste**

Refuse removal shall be performed by the Mossel Bay Municipality. A dedicated solid waste collection facility shall be provided and designed to the satisfaction of the Mossel Bay municipality. Solid waste removal to be included in- and performed in accordance with a signed services agreement.

### **3.7 Electricity**

#### **3.7.1 Bulk Supply**

The bulk electrical services to the development will be provided by the Mossel Bay Municipality from the existing Hartenbos North (11/11kV) Switching Station, which is located along Monte Christo Road, Hartenbos. This substation has recently been constructed by the Mossel Bay Municipality, specifically for providing bulk electrical power to all planned developments within this area. The position of the planned Hartland 2 development, relative to the substation position, is indicated in the figure below.

The Developer will be responsible for the provision of two (2) new 11kV, air-insulated circuit breakers, to be added onto the existing 11kV switchboard within the Hartenbos North (11/11kV) Switching Station. Sufficient space has been allowed for in this substation for the addition of future circuit breakers, which means that the building will not need to be extended. A project has already been initiated by the Developer as part of the provision of the Bulk Electrical (MV) Supply to the Hartland 1 development for the installation of the two (2) new circuit breakers within the Hartenbos Noord Substation. The same circuit breakers will be used to also supply the Hartland 2 development.

From the new 11kV circuit breakers, the Developer will be responsible for the installation of an 11kV underground cable ring network to the erf boundary of the planned development. A project has already been initiated by the Developer as part of the provision of the Bulk Electrical (MV) Supply to the Hartland 1 development for the installation of 1x 11kV, 150 mm<sup>2</sup>, 3-core, Copper, PILC cable (rated 280A, 5.4 MVA @ 11kV) along the Western Access Road. As part of this project, a second 11kV cable (with the same rating and a length of 300m) will be installed in the same trench from the Hartenbos Noord Substation to the Monte Christo / R102 crossing and then turning east along the R102 in the direction of the new Hartland 2 development and will be left coiled and energized in the trench, until such time as the new development is constructed and the bulk supply being required.




Figure 14: Bulk Electrical (MV) Supply Network

A new 4-way Ring Main Unit (RMU), which will also be supplied by the Developer, will serve as the main supply (and metering) point, from where the rest of the development's medium and low voltage networks will be supplied. The proposed position of this new RMU will be in close proximity to the main entrance to the development. Once the new RMU has been installed, the final sections of 11kV, 150 mm<sup>2</sup>, 3-core, Copper, PILC cable between the RMU's for Hartland 1 and Hartland 2 developments will be installed (as indicated in the figure above) to complete the ring network from the Hartenbos Noord Substation to the two Hartland developments. This ring network will be dedicated for the Hartland developments and will not be shared with other future developments in the area.

It is important to note that there are currently no dedicated cable routes and/or servitudes along the R102, between the Hartenbos North (11/11kV) Switching Station and the planned development. This will have to be negotiated with the relevant parties and landowners during the planning stage of the project.

### 3.7.2 Maximum Demand

Based on the latest proposed layout plans, the following table provides an estimate of the number of units as well as the estimated load per category, based on the area allocated. The following major sub-divisions of development have been allowed for:

Category B: Hospital

Category C: Secondary Schools with Hostel and Sport Fields

## Category D: Tertiary Education with Hostel and Sport Fields

Description	Area	Units	Total Load Before Diversity (kVA)	Diversity	Total Load After Diversity (kVA)
<b>Category B</b>					
Hospital	17162m <sup>2</sup>	1	1090	0.8	872
<b>Category C</b>					
Secondary School	8582m <sup>2</sup>	1	423	0.7	296
School Sport Field Lighting		1	109	0.8	87
School Hostels	1289m <sup>2</sup>	1	107	0.9	96
<b>Category D</b>					
Tertiary Education Centre		1	302	0.7	211
Student Accommodation		1	107	0.9	96
Sports Facilities		1	20	0.8	16
<b>TOTAL</b>			<b>2168</b>		<b>1680</b>

Figure 15: Estimated Load per Category

The estimated After Diversity Maximum Demand (ADMD) for the entire development, catering for all the different categories as well as some general electrical load (street lighting, public lighting, pump stations, etc.), as per accepted design assumptions, criteria and standards, is estimated to be 1.7 MVA. This capacity is currently available at the Hartenbos North (11/11kV) Switching Station. A confirmation letter has been requested from the Mossel Bay Municipality.

### 3.7.3 Internal Medium Voltage (MV) Reticulation

The internal MV reticulation will be in the form of an underground cable ring network, connecting to various mini-substations, strategically located throughout the estate. It is recommended that separate minisubs be provided for each of the different categories, i.e. hospital, secondary school and tertiary education. The developer will be responsible for the installation of the MV infrastructure from the bulk connection point (ring main unit). Mossel Bay Municipality will by default not take over the internal MV network and the developer will remain responsible for all operations and maintenance of the entire network.

### 3.7.4 Internal Low Voltage (LV) Reticulation

An internal low voltage reticulation network will be provided from the minisubs to standard street-front kiosks and/or distribution boards. All LV cabling and service connections will be installed underground. It is recommended that the metering for the individual premises be in the form of Pre-Paid Metering, where the meters will be installed in the kiosks and customer interface unit will be installed in the client's building.

A specific service provider will be appointed to install the pre-paid meters and to manage the vending of electricity sales on behalf of the developer.

Mossel Bay Municipality will by default not take over the internal LV network and revenue metering to customers as the developer will remain responsible for all operations and maintenance of the entire network.

### **3.7.5 Street Lighting**

Decorative and energy saving street lighting will be provided for the development and will be supplied from the closest minisub. Streetlights will be controlled via day-night sensors and switches.

### **3.7.6 Data Reticulation**

A data reticulation sleeve network will be provided as part of the detail design and construction phase of the project. This will include all the required PVC sleeves and manholes from a central connection point at the entrance to the development, all the way to each individual site. It is important to note that no data cabling (fibre optic) will be allowed for as part of the initial development, but only the back-bone infrastructure will be installed as part of the bulk services installation for the development. This will ensure that when a fibre network service provider is appointed at some point in the future, all the infrastructure will be in place for them to only install the fibre cables and that no roads or other bulk infrastructure services will be damaged in the process of doing so.

## 4 CONCLUSIONS AND RECOMMENDATIONS

---

### 4.1 Conclusions

The following conclusions can be reached from the High Level Bulk Engineering Services Report on the development of Hartland II (Jakkalskop) Estate on Remainder of farm Vaale Valley 219, Mossel Bay:

1. A services agreement (SA) will be signed between the developer and the municipality on conclusion of the EIA and townplanning processes. This bulk services engineering report, as well as inputs from the EIA and townplanning processes, will form the basis of the SA.
2. The in-situ materials found on site are adequate for the construction of engineering services and foundations for residential and commercial development.
3. Water:
  - a. The Average Annual Daily Demand (AADD) for the development, in line with accepted design consumptions, assumptions, criteria and standards, is 337kl/day.
  - b. Bulk water is available for this development. A letter of confirmation has been requested from the Mossel Bay Municipality.
  - c. The development is serviced by the new municipal 7MI Jakkalskop Reservoir, situated centrally on the highest point on the proposed development.
  - d. The new Jakkalskop reservoir feeds into a new 500mm municipal uPVC bulk water line that has recently been constructed along the R102 (MR344) on the south eastern boundary of the development.
  - e. The bulk water connection to the development may be at any of a number of positions, along the new 500mm line. The bulk water connection for the school and hospital will be from a new line along the new access road. The bulk water connection for the tertiary education centre is proposed at a point adjacent to the centre on the R102 (MR344).
4. Sewer:
  - a. The proposed development spans over a number of watersheds and a number of drainage zones are identified. Each zone will be serviced with a gravity sewer network and pump station. The primary drainage zone drains towards the southernmost corner of the site adjacent to the R102 (MR344).
  - b. The Average Dry Weather Flow (ADWF) of the development, in line with accepted design criteria and standards, is 304kl/d.
  - c. The site is not serviced by a municipal sewer connection or a municipal sewer network in close vicinity.

- d. A new main sewer pump station (Pump Station 1 – PS1) shall be constructed in the southern corner of the proposed development.
  - e. Sewer will be pumped from here to the Hartenbos Regional WWTW with a new pressure line.
  - f. Hartenbos regional WWTW has sufficient capacity to accommodate the bulk sewer from the development. A letter of confirmation has been requested from the Mossel Bay Municipality.
5. Roads & access
- a. Primary access for phase 1 will be obtained from km2.763 at the existing formalized Hartland Estate access. Secondary access for phase 1 will be obtained from km2.299. Sight distances at these accesses to the development are excellent in both directions in both the horizontal and vertical alignments.
  - b. The necessary applications will be required to be lodged to the Provincial Roads Authority for the formalization of these accesses.
  - c. The access configuration for the accesses onto the R102 (MR344) will trigger right turn lanes on the R102 (MR344).
  - d. A Traffic Impact Assessment (TIA) will be required to be conducted for the development. The TIA will be required to be conducted in line with all provincial and municipal prescriptions and guidelines.
  - e. The provision of public transport facilities like minibus-taxi drop-off facilities to be investigated on the R102 (MR344) at the access points to the development.
  - f. Sufficient parking shall be provided on the SDP of the proposed development in line with all municipal guidelines. Parking shall be provided for disabled persons at all public and/or commercial facilities.
6. Stormwater:
- a. The proposed development spans over a number of watersheds and a number of drainage zones are identified. Each zone will be serviced with a formal stormwater network. The primary drainage zone drains towards the southernmost corner of the site adjacent to the R102 (MR344). The secondary drainage zone drains towards the Little Brak River to the east.
  - b. For the primary drainage area, stormwater will be collected in a detention pond on the lowest point of the site on the southern corner. Stormwater will drain south-west in a dedicated concrete culvert, underneath Monte Christo Road, where it will drain into the existing municipal detention pond on the municipal erf (Ptn 101 of Farm 217). Drainage from the municipal detention pond is into the Hartenbos River. For the secondary drainage area, stormwater will drain directly into the Little Brak River.
  - c. A formal stormwater reticulation system will be provided by a combination of surfaced roadways, kerbs, channels, cut-off drains, stormwater pipes, detention ponds and various minor structures. Energy dissipation will be performed as standard practice with gabion mattresses at all outlets. All pipe outlets will be standard concrete headwalls. Litter traps will be

provided at all stormwater outlets and will be cleaned on a regular basis by the estate's landscaping and maintenance teams.

7. Solid waste:

- a. Refuse removal shall be performed by the Mossel Bay Municipality. A dedicated solid waste collection facility shall be provided and designed to the satisfaction of the Mossel Bay municipality. Solid waste removal to be included in- and performed in accordance with a signed services agreement.

8. Electricity:

- a. The bulk electrical services to the development will be provided by the Mossel Bay Municipality from the existing Hartenbos North (11/11kV) Switching Station, which is located along Monte Christo Road, Hartenbos. This substation has recently been constructed by the Mossel Bay Municipality, specifically for providing bulk electrical power to all planned developments within this area.
- b. The Developer will be responsible for the provision of two (2) new 11kV, air-insulated circuit breakers, to be added onto the existing 11kV switchboard within the Hartenbos North (11/11kV) Switching Station. Sufficient space has been allowed for in this substation for the addition of future circuit breakers, which means that the building will not need to be extended. A project has already been initiated by the Developer as part of the provision of the Bulk Electrical (MV) Supply to the Hartland 1 development for the installation of the two (2) new circuit breakers within the Hartenbos Noord Substation. The same circuit breakers will be used to also supply the Hartland 2 development.
- c. From the new 11kV circuit breakers, the Developer will be responsible for the installation of an 11kV underground cable ring network to the erf boundary of the planned development. A project has already been initiated by the Developer as part of the provision of the Bulk Electrical (MV) Supply to the Hartland 1 development for the installation of 1x 11kV, 150 mm<sup>2</sup>, 3-core, Copper, PILC cable (rated 280A, 5.4 MVA @ 11kV) along the Western Access Road. As part of this project, a second 11kV cable (with the same rating and a length of 300m) will be installed in the same trench from the Hartenbos Noord Substation to the Monte Christo / R102 crossing and then turning east along the R102 in the direction of the new Hartland 2 development and will be left coiled and energized in the trench, until such time as the new development is constructed and the bulk supply being required.
- d. A new 4-way Ring Main Unit (RMU), which will also be supplied by the Developer, will serve as the main supply (and metering) point, from where the rest of the development's medium and low voltage networks will be supplied. The proposed position of this new RMU will be in close proximity to the main entrance to the development. Once the new RMU has been installed, the final sections of 11kV, 150 mm<sup>2</sup>, 3-core, Copper,

PILC cable between the RMU's for Hartland 1 and Hartland 2 developments will be installed to complete the ring network from the Hartenbos Noord Substation to the two Hartland developments. This ring network will be dedicated for the Hartland developments and will not be shared with other future developments in the area.

- e. The estimated After Diversity Maximum Demand (ADMD) for the entire development, catering for all the different categories as well as some general electrical load (street lighting, public lighting, pump stations, etc.), as per accepted design assumptions, criteria and standards, is estimated to be 1.7 MVA. This capacity is currently available at the Hartenbos North (11/11kV) Switching Station. A confirmation letter has been requested from the Mossel Bay Municipality.
- f. The internal MV reticulation will be in the form of an underground cable ring network, connecting to various mini-substations, strategically located throughout the estate. The developer will be responsible for the installation of the MV infrastructure from the bulk connection point (ring main unit).
- g. An internal low voltage reticulation network will be provided from the minisubs to standard street-front kiosks. All LV cabling and service connections will be installed underground.
- h. Decorative and energy saving street lighting will be provided for the development and will be supplied from the closest minisub. Streetlights will be controlled via day-night sensors and switches.
- i. A data reticulation sleeve network will be provided.

It can holistically be concluded that the proposed development can be designed and constructed to acceptable specifications and standards from an engineering design perspective.

## **4.2 Recommendations**

It is the holistic recommendation that the proposed development be approved from an engineering design perspective.

## **5 ADDENDA**

---

**5.1 Addendum 1: Site Development Plan**

**5.2 Addendum 2: Preliminary Bulk Engineering Services Design Drawings**

**5.3 Addendum 3: Municipal Confirmation Letters**






<p>82 Victoria Street George, 6520 South Africa Tel: +27 44 864 1138 Fax: +27 44 864 1185 E: dalmar@dalmar.co.za</p>	<p>1973 <b>DALMAR</b></p>	<p><b>ELEMENT</b> Consulting Engineers A FIFTH DIMENSION TO ENGINEERING</p>	<p>Project: <b>SUID-KAAP LANDGOED PORTION OF FARM 219, VAALLE VALLEI</b></p> <p>Plan Description: <b>ROADS LAYOUT</b></p>	<p>Scale: 1:2000 Original Size: <b>A1</b> Drawing No.: 24006 Contract No.: 24006</p>	<p>Author: MP Checked: MP Approved: HL</p>	<p>Signature: _____ Name: _____ Title: _____</p>	<p>Revised: _____ By: _____ Date: _____</p>
--	-------------------------------	---	---	--	--	--	---



<p>CONNECT TO INLET WORKS ELEVATION = 19m</p> <p>HARTLANDS REGIONAL WASTEWATER TREATMENT WORKS</p> <p>HIGH POINT ELEVATION = 24m</p> <p>1500mm CLASS 12 uPVC PRESSURE SEWER LINE TO WWTW</p> <p>NEW VINTAGE RESIDENTIAL PROPOSED SEWER PUMP STATION</p> <p>NEW VINTAGE RESIDENTIAL PRESSURE SEWER LINE ROUTE TO BE APPROVED BY NEW VINTAGE RESIDENTIAL</p> <p>INSET A SCALE 1:5000</p> <p>REFER TO INSET A</p>	<p>LEGENDA</p> <ul style="list-style-type: none"> <li>SEWER GRAVITY LINE</li> <li>SEWER PRESSURE LINE</li> <li>SEWER MANHOLE</li> <li>SEWER PUMP STATION</li> </ul>	<p>Scale</p> <p>1:2000</p> <p>Original Size A1</p> <p>Contract No. 24006</p> <p>Drawing No. 24006C/S01</p> <p>Revision A</p> <p>COMPRESSED BY THE SURVEY GENERAL, THE SURVEY GENERAL (PVT) LTD IN TERMS OF THE COMPANIES ACT, 1973 OF 1973.</p>																																	
<p>Project</p> <p>SUID-KAAP LANDGOED PORTION OF FARM 219, VAALLE VALLEI</p> <p>Plan Description</p> <p>SEWER RETICULATION LAYOUT</p>	<p>Client/Author</p>	<p>82 Victoria Street George, 6200 George, 6200 Tel: +27 44 864 1138 Fax: +27 44 864 1105 E: dalmar@dalmar.co.za</p>																																	
<table border="1"> <thead> <tr> <th>Rev.</th> <th>Date</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>21/03/2024</td> <td>FOR SERVICE ENGINEER</td> </tr> </tbody> </table>	Rev.	Date	Description	A	21/03/2024	FOR SERVICE ENGINEER	<table border="1"> <thead> <tr> <th>Drawn</th> <th>Checked</th> <th>Approved</th> <th>Pr. No.</th> </tr> </thead> <tbody> <tr> <td>MP</td> <td>MP</td> <td>HL</td> <td></td> </tr> <tr> <td>MP</td> <td>MP</td> <td>HL</td> <td></td> </tr> </tbody> </table>	Drawn	Checked	Approved	Pr. No.	MP	MP	HL		MP	MP	HL		<table border="1"> <thead> <tr> <th>Design</th> <th>Drawn</th> <th>Checked</th> <th>Approved</th> <th>Pr. No.</th> </tr> </thead> <tbody> <tr> <td>MP</td> <td>MP</td> <td>HL</td> <td>HL</td> <td></td> </tr> <tr> <td>MP</td> <td>MP</td> <td>HL</td> <td>HL</td> <td></td> </tr> </tbody> </table>	Design	Drawn	Checked	Approved	Pr. No.	MP	MP	HL	HL		MP	MP	HL	HL	
Rev.	Date	Description																																	
A	21/03/2024	FOR SERVICE ENGINEER																																	
Drawn	Checked	Approved	Pr. No.																																
MP	MP	HL																																	
MP	MP	HL																																	
Design	Drawn	Checked	Approved	Pr. No.																															
MP	MP	HL	HL																																
MP	MP	HL	HL																																



**LEGEND**

- STORMWATER LINE
- STORMWATER NATURAL DRAINAGE COURSE
- STORMWATER MANHOLE
- STORMWATER RESIGNALL OUTLET
- STORMWATER RETENTION POND

Scale	1:2000
Sheet	ORIGINAL SIZE A1
Contract No.	24006
Drawing No.	24006/C/SW01
Revision	A

Copyright © 2024 by DALMAR CONSULTING ENGINEERS (Pty) Ltd. All rights reserved. This drawing is the property of DALMAR CONSULTING ENGINEERS (Pty) Ltd.

Designed	MP	Name	MP	Signature	
Drawn	MP	Checked	HL		
Approved	HL	Pr. No.			
Project: SUID-KAAP LANDGOED PORTION OF FARM 219, VAALE VALLEI					
Plan Description: STORMWATER RETICULATION LAYOUT					
					
82 Victoria Street George, 6520 Phone: +27 44 864 1138 Fax: +27 44 864 1105 E: dalmar@dalmar.co.za					
					
A FIFTH DIMENSION TO ENGINEERING					
Rev.	Date	Description	MP	HL	By
A	21/06/2024	FOR SERVICE REPORT			




Author	MP	1:2000	Sheet	Original Size A1
Drawn	MP	2:4006	Contract No.	24006
Checked	HL		Drawing No.	24006/CW01
Approved	HL		Revision	A
Pr. No.			COPYRIGHT IN THE DESIGN AND DRAWINGS OF THIS PROJECT BELONGS TO DALMAR ENGINEERING (PTY) LTD IN TERMS OF THE COPYRIGHT ACT, 1962 OF 1962.	


Designed	MP	1:2000	Signature	
Drawn	MP	2:4006		
Checked	HL			
Approved	HL			

**Project**  
**SUID-KAAP LANDGOED**  
**PORTION OF FARM 219, VALE VALLEY**

**Plan Description**  
**WATER RETICULATION LAYOUT**



82 Victoria Street  
 George, 6520  
 Phone: 027 44 864 1138  
 Fax: 027 44 864 1105  
 E-Mail: info@dalmar.co.za



Rev.	Date	Description	By	MP
A	21/06/2025	FOR SERVICE REPORT		